





# GAS SAFETY INSPECTION

This form is not to be used as a Landlord's Gas Safety Record and the details recorded below do not confirm that the installation was installed by a Registered Installer or that the installation complies with Building Regulations.

Job No:   
 Invoice no:

**Registered Business Details (REG NO)** 11724  
 Company Booth + Bonford Ltd  
 Gas Operative Licence No. 3330453  
 Address Unit 2 Mead Rd  
Cheltenham Glos  
 Postcode GL53 7EF Tel No. 588220

**Job Address**  
 Name (Mr/Mrs/Miss/Ms) \_\_\_\_\_  
 Address 33 Querna Road  
Cirencester.  
 Postcode \_\_\_\_\_ Tel No. \_\_\_\_\_  
 Rented accommodation state Yes or No

### Gas Installation

	Yes/No	DETAILS
Is the installation gas tight?	<input checked="" type="checkbox"/>	<u>YES</u>
Have the correct materials been used in the installation?	<input checked="" type="checkbox"/>	<u>YES</u>
Is the installation pipework correctly sized?	<input checked="" type="checkbox"/>	<u>YES</u>
Where appropriate, has protective electrical bonding been carried out?	<input checked="" type="checkbox"/>	<u>YES</u>

### Emergency Control(s)

	Yes/No	DETAILS
Is the emergency control valve(s) correctly positioned/accessible?	<input checked="" type="checkbox"/>	<u>YES</u>
Is the emergency control valve(s) labelled?	<input checked="" type="checkbox"/>	<u>YES</u>

### Appliance Details

Type	Make	Model	Flue type OF/RS/FL	Chimney condition and termination satisfactory Yes/No/NA	Flue performance checks Pass/Fail/NA	Is ventilation satisfactory? Yes/No	Operating pressure in mbars or heat input kW or Btu/h	Combustion analyser reading (if applicable)	Appliance safe to use Yes/No
<u>Boiler</u>	<u> Worcester</u>	<u>Greenstar 28i junior</u>	<u>RS</u>	<u>YES</u>	<u>PASS</u>	<u>YES</u>	<u>19.5</u>	<u>YES</u>	<u>YES</u>
/									

### Findings

Is the gas installation safe for use?	<input checked="" type="checkbox"/>		<input type="checkbox"/>	Have warning labels been affixed?
If No, issue a Warning/Advice Notice (insert serial No.) <span style="border: 1px solid black; display: inline-block; width: 100px; height: 15px;"></span>				Is any remedial work required? <input type="checkbox"/>

**Details of remedial work required** \_\_\_\_\_  
Serviced as per manufacture - OK.  
 \_\_\_\_\_  
Heating pressure was down - now topped up to 1.4 bar OK.  
 \_\_\_\_\_

Gas user signature _____	Gas operative signature <u>D Page</u>
Print name _____	Print name <u>D PAGE</u>
Date _____	Date <u>22/7/14</u>

Copyright © CORGI/direct August 2013. The format and layout of this document may not be reproduced in any manner without the prior written consent.

Gas Safe is a registered trade mark of the HSE and is used under licence.