

Plant Commissioning Record

Bosch Thermotechnology
Cotswold Way
Warndon, Worcester
WR4 9SW
Tel: 0870 421 5933

Gas Safe No: 18091



BOSCH

Date	14/10/2014	Engineer Code	05DW	Engineer name	David Wreford
Notification no1	308555903	2	308555909	3	4
6	7	8			5

Site Address:	
Name:	Cotswold District Council
Address:	Council Offices-IT Suite Trinity Road. Cirencester.
Post code:	GL7 1PX

Installation Company	
Name:	
Tel:	
Post Code	

Boiler	No 1	No 2	No 3	No 4	No 5	No 6	No 7	No 8
Boiler type	GB162	GB162						
Output kW	80	80						
CO ₂ (%) Max	9.1	9.1						
CO ₂ (%) Min	8.4	8.4						
CO (ppm) Max	62	64						
CO (ppm) Min	0	0						
Flue temp (°C)	53	54						
NO _x (ppm)	19	21						
Gas/air ratio	-0.04	-0.02						
Efficiency (%)	98.4	98.5						
Gas Inlet Pressure	19.5	19.3						

boiler 1 ser no:	3290-455-000062-87470248	boiler 2 ser no:	3290-455-000057-87470248
boiler 3 ser no:		boiler 4 ser no:	
boiler 5 ser no:		boiler 6 ser no:	
boiler 7 ser no:		boiler 8 ser no:	

Ventilation OK	High	Yes	Low	Yes	Mechanical ventilation interlocked	n/a
Gas booster installed/operating correctly				n/a	Gas pipework OK	Yes

Engineer Comments

Commission Cascade pair of GB162-80kw frame mounted Condensing Boilers each fitted with a Pump Group and connected to the single Heating circuit via a Low Loss Header. Boilers enabled Volt Free on/off from the existing control panel connected to the green plug on the Boiler Connection Board.

Responsible person on site	
Name:	
Tel:	

Was a warning notice issued	No
Boiler left operating?	Yes
Installation safe to use?	Yes



BOSCH

Buderus

Bosch Group

WORCESTER

Bosch Group